

Issues

#	Project	Tracker	Status	Priority	Subject	Assignee	Updated
23120	CRV FEB test software	Bug	New	Normal	I put in temporary host-based ramp speed limit, should be optional		08/14/2019 12:00 PM
23119	CRV FEB test software	Bug	New	Normal	Thinks all bias calibrations are bad		08/14/2019 11:57 AM
23118	CRV FEB test software	Feature	New	Normal	No identification of bad bias or mux on display		08/14/2019 11:56 AM
12846	uBooNE DAQ	Feature	New	Normal	Add Ganglia slowmon timeout based on "TN" field in ganglia data	Glenn Horton-Smith	06/03/2016 10:28 AM
12146	uBooNE slowmon analysis	Feature	New	Normal	Import from other data sources		04/01/2016 01:49 PM
12145	uBooNE slowmon analysis	Feature	New	Normal	Quick, convenient date <-> unixtime conversion tool		04/01/2016 01:46 PM
12143	uBooNE slowmon analysis	Feature	New	Normal	Better UI, especially for on-shift peopl		04/01/2016 01:42 PM
12142	uBooNE slowmon analysis	Feature	New	Normal	Support different aggregate functions in binned data		04/01/2016 01:41 PM
10467	uBoone Operations	Feature	Closed	Normal	Add DAQ's "Builder-Frame_Counter_Diff_Max_Aassemblerappevb" metric to slowmon	Glenn Horton-Smith	10/17/2015 05:36 PM
10426	uBoone Operations	Feature	Closed	Normal	Don't alarm some uB EPICS beam channels when beam current low	Glenn Horton-Smith	10/24/2015 01:39 PM
10425	uBoone Operations	Feature	Closed	Normal	Flasher and calibration board power should normally be off, set alarm ranges accordingly, except current	Glenn Horton-Smith	10/09/2015 04:40 PM
10411	IFBeam	Bug	Closed	Normal	Timestamps are wrong when "bin" feature is used	Vladimir Podstavkov	07/31/2017 10:55 AM
10385	uBoone Operations	Support	Closed	Normal	Add various things to BEAM subsystem	Glenn Horton-Smith	10/05/2015 03:33 PM
10384	uBoone Operations	Support	Closed	Normal	Restore low voltage channel 506 (flasher supply) to alarm system	Glenn Horton-Smith	10/06/2015 06:48 PM
10383	uBoone Operations	Feature	Closed	Normal	calculate run restarts per interval and run uptime from run number variable in slowmon	Glenn Horton-Smith	10/22/2015 04:36 PM
10377	uBoone Operations	Support	Closed	Normal	Adjust rack temperature alarm ranges to be consistent with steady running	Glenn Horton-Smith	10/02/2015 02:01 PM
10376	uBoone Operations	Support	Closed	Normal	Adjust purity monitor alarm ranges, add new calculations	Glenn Horton-Smith	10/02/2015 02:25 PM
10243	uBooNE DAQ	Idea	New	Normal	near real time ifbeam efficiency info		09/21/2015 05:45 PM
9212	uBoone Operations	Feature	Closed	Normal	Add NuMI horn current to things we monitor in Beam subsystem	Glenn Horton-Smith	10/05/2015 03:07 PM
9206	uBoone Operations	Necessary Maintenance	Closed	Normal	Adjust PMT HV supply monitoring ranges	Glenn Horton-Smith	10/02/2015 02:59 PM
9082	uBoone Operations	Feature	New	Normal	Improvements to Alarm Area Panel and Alarm Tree for improved status visibility		06/09/2015 03:41 PM
9080	uBoone Operations	Feature	Closed	Normal	Add Rack Protection Status latch and overtemp status latch to rack monitor IOC	Glenn Horton-Smith	10/02/2015 02:27 PM
9077	uBoone Operations	Bug	Closed	Normal	Remove DAQ status from alarm tree temporarily	Glenn Horton-Smith	06/09/2015 09:47 AM
9066	uBoone Operations	Feature	Closed	High	Secure Wiener write-access with new community name	Glenn Horton-Smith	10/02/2015 02:37 PM
9023	uBoone Operations	Bug	New	High	investigate high Wiener internal temperatures in PL508 (CrateRails) supplies	Sowjanya Gollapinni	06/03/2015 11:47 AM
9022	uBoone Operations	Feature	Closed	Normal	add Wiener internal temperatures, "behavior" variables to archive	Glenn Horton-Smith	10/02/2015 08:05 PM

#	Project	Tracker	Status	Priority	Subject	Assignee	Updated
9021	uBoone Operations	Bug	Closed	Normal	Remove non-existent fan pack from slow controls for ELIZabeth and TPC5 racks	Glenn Horton-Smith	06/05/2015 10:12 PM
8990	uBoone Operations	Bug	Closed	Normal	Cannot acknowledge alarms after update to new version of control system gui	Glenn Horton-Smith	06/01/2015 10:51 AM
8989	uBoone Operations	Bug	Closed	Normal	Archived data not shown on rack fan speed and temperature panels	Glenn Horton-Smith	06/01/2015 10:52 AM
8398	uBoone Operations	Feature	Closed	Normal	Upgrade CSS gui to 3.3.10a (NSLS2 version) for good pv-table save/restore tool	Glenn Horton-Smith	06/01/2015 02:43 AM
8367	uBoone Operations	Necessary Maintenance	Closed	Urgent	Add and archive channels for feedthrough temperatures, heaters	Glenn Horton-Smith	05/17/2015 07:59 PM
8332	uBoone Operations	Bug	Closed	High	Add more Wiener channels to archiver	Glenn Horton-Smith	04/13/2015 08:26 PM
8179	uBoone Operations	Bug	Closed	Normal	On slowmon CSS overview panel, fix order of LSR1, LSR2, PM3, and Cryo racks	Glenn Horton-Smith	04/16/2015 11:03 AM
8152	uBoone Operations	Necessary Maintenance	Closed	Normal	review daq, pc status, and related alarm ranges		10/02/2015 08:01 PM
8151	uBoone Operations	Necessary Maintenance	Closed	Normal	review all crate temperature and fan speed alarm ranges		10/02/2015 08:01 PM
8150	uBoone Operations	Necessary Maintenance	Closed	Normal	review all our power supply alarm ranges		10/02/2015 08:00 PM
8149	uBoone Operations	Necessary Maintenance	Closed	Normal	review all our read-only cryogenics status alert ranges	Glenn Horton-Smith	10/02/2015 03:07 PM
8143	uBoone Operations	Feature	Closed	Normal	Test and document use of EPICS channel save/restore tool	Glenn Horton-Smith	10/02/2015 09:13 AM
8142	uBoone Operations	Feature	Closed	Normal	Make cryo readonly vars invalid if data is too old	Glenn Horton-Smith	03/23/2015 11:39 AM
8141	uBoone Operations	Feature	Closed	Normal	Complete slowmoncon expert docs on EPICS and CSS setup	Glenn Horton-Smith	10/02/2015 09:28 AM
8140	uBoone Operations	Necessary Maintenance	Closed	Normal	review all slowmoncon alarms	Glenn Horton-Smith	10/02/2015 08:04 PM
8110	uBooNE DAQ	Feature	Closed	Normal	Switch to Postgres 9_2_4 server	Andrzej Szalc	03/18/2015 10:51 AM
7866	uBoone Operations	Necessary Maintenance	Closed	Normal	Check on TPC R4 fanpack	Glenn Horton-Smith	03/21/2015 02:48 PM
7551	uBoone Operations	Necessary Maintenance	Closed	Normal	Check temperature probe #2 in LASER-1 rack	Thomas Strauss	03/21/2015 02:49 PM