

AD ESH Department, Interlocks Group - Feature #21840

Unified LEPR/PLC Protocol

02/05/2019 08:42 AM - Beau Harrison

Status:	New	Start date:	02/05/2019
Priority:	Normal	Due date:	
Assignee:		% Done:	0%
Category:		Estimated time:	0.00 hour
Target version:		Spent time:	0.00 hour
Description			
Currently, the LEPRs and the PLCs speak different protocol structures to the Safety System Server. It would be nice for these to be unified. We are limited by the options provided by the PLCs. OPC-UA seems to have potential but may provide many more features than we need.			