

## uBoone Operations - Necessary Maintenance #8723

### Put LArTF network connection on UPS

05/12/2015 02:14 PM - Matthew Toups

<b>Status:</b>	New	<b>Start date:</b>	05/12/2015
<b>Priority:</b>	High	<b>Due date:</b>	
<b>Assignee:</b>		<b>% Done:</b>	0%
<b>Category:</b>		<b>Estimated time:</b>	0.00 hour
<b>Target version:</b>		<b>Spent time:</b>	0.00 hour
<b>Description</b>			
An initial meeting with FNAL networking support determined the type of UPS needed to provide the LArTF network with power for ~45 minutes in the event of a power outage. This was requested by the cryo group so that they can remotely control the cryo system (rather than going physically to the pit) and put the detector in a safe state in the event of an unplanned power outage.			

#### History

#1 - 05/14/2015 02:38 PM - Matthew Toups

- Priority changed from Normal to High