

Erlang Front-end Framework - Issues

#	Tracker	Status	Priority	Subject	Assignee	Updated
25290	Bug	Assigned	Normal	resint crashes if a udp:send fails	Dennis Nicklaus	12/07/2020 02:53 PM
24938	Bug	New	Normal	Gracefully handle ACNET startup errors.		09/09/2020 03:51 PM
24319	Bug	Closed	Normal	clean up erlang driver code (unused vars and deprecated methods)	Jianming You	09/09/2020 03:38 PM
24293	Bug	Closed	Normal	Device Alarms from readback errors post even when alarm is bypassed	Dennis Nicklaus	04/08/2020 12:53 PM
23441	Bug	Closed	Normal	erlang:reason undefined, used in ps_bira driver	Jianming You	09/09/2020 03:39 PM
22702	Bug	Assigned	Normal	Problem with LLRF OTSDaq interface process not dying	Dennis Nicklaus	06/07/2019 05:22 PM
22377	Bug	Closed	Normal	Can't fast time plot guaranteed readable devices	Jerry Firebaugh	09/04/2019 03:02 PM
22081	Bug	Closed	Normal	gets32 reading on states can't work in erlang frontend	Richard Neswold	03/15/2019 09:45 AM
22038	Bug	Closed	Normal	CLX58E reports rd_crash alarms repeatedly	Richard Neswold	03/15/2019 09:41 AM
21882	Bug	Closed	Normal	inappropriate messages getting to ftp plt cont_main process	Jerry Firebaugh	03/25/2019 02:01 PM
21797	Bug	Closed	Normal	system_driver crashed on clx38 --- "blocked_normal"	Pierrick Hanlet	03/15/2019 09:34 AM
21796	Bug	Assigned	Normal	ps_lxi_driver problems with init -- undef	Richard Neswold	01/30/2019 01:29 PM
21708	Bug	Assigned	Urgent	LXI PS Driver is occasionally returning [57 -107] when setting	Richard Neswold	02/04/2019 01:19 PM
21672	Bug	Feedback	High	ps_lxi_driver downloads problem at startup, alarms fail	Richard Neswold	10/25/2019 12:42 PM
21493	Bug	Assigned	Normal	iota_magnet_comb_drv repeatedly crashes	Jianming You	12/06/2018 11:26 AM
21492	Bug	New	Normal	When dev_registry restarts all drivers because one driver crashes too much, settings don't get downloaded		12/06/2018 05:04 PM
21153	Bug	Closed	Normal	add_erl_devault_devices is not compliant with current dabel	Dennis Nicklaus	10/15/2018 01:15 PM
20617	Bug	Assigned	Normal	Fix remaining issues with SG power supplies	Richard Neswold	11/21/2018 03:29 PM
19477	Bug	Closed	Normal	Alarms don't repost after a BigClear if TNeeded> 1.	Dennis Nicklaus	06/07/2018 01:49 PM
19342	Bug	Closed	Normal	swap int and swap uint alarm value conversions are wrong	Dennis Nicklaus	06/07/2018 01:51 PM
18118	Bug	Feedback	Normal	copyset localapp dpmclient disconnects sometimes don't reconnect automatically.	Dennis Nicklaus	11/30/2018 02:16 PM
18041	Bug	Closed	Normal	Alarmblocks where datatype is initially wrong can't be fixed in erlang frontend without reboot	Dennis Nicklaus	01/14/2019 03:12 PM
17394	Bug	Closed	Normal	Settings forwarding does not work if you have a constant stream of new settings for the same device	Dennis Nicklaus	11/30/2018 05:26 PM
16222	Bug	Closed	Normal	modbus front-ends show over 1s delay in reading response since 2/28/17, possibly correlated with bigsave	Jerry Firebaugh	04/21/2017 09:33 AM
16193	Bug	Closed	Normal	Alarm blocks with "Tries Needed" set to 0 don't work.	Richard Neswold	10/26/2017 03:05 PM
15875	Bug	Closed	Normal	motion_cntl has spurious fread errors	Jerry Firebaugh	10/27/2017 11:29 AM
14805	Bug	Assigned	Normal	erl-modbus device occasionally see long delays	Dennis Nicklaus	11/21/2018 02:53 PM
14643	Bug	Closed	Normal	Can't build acsys-fe-dev-acqiris on FGATE	Dennis Nicklaus	11/23/2016 04:14 PM
13449	Bug	Closed	Normal	add_erl_default_devices generates a bad PDB PRBSTS line	Richard Neswold	08/05/2016 11:25 AM