

## uBoone Operations - Issues

#	Tracker	Status	Priority	Subject	Assignee	Updated
10467	Feature	Closed	Normal	Add DAQ's "Builder-Frame_Counter_Diff_Max_Assemblerappevb" metric to slowmon	Glenn Horton-Smith	10/17/2015 05:36 PM
10426	Feature	Closed	Normal	Don't alarm some uB EPICS beam channels when beam current low	Glenn Horton-Smith	10/24/2015 01:39 PM
10425	Feature	Closed	Normal	Flasher and calibration board power should normally be off, set alarm ranges accordingly, except current	Glenn Horton-Smith	10/09/2015 04:40 PM
10383	Feature	Closed	Normal	calculate run restarts per interval and run uptime from run number variable in slowmon	Glenn Horton-Smith	10/22/2015 04:36 PM
9212	Feature	Closed	Normal	Add NuMI horn current to things we monitor in Beam subsystem	Glenn Horton-Smith	10/05/2015 03:07 PM
9080	Feature	Closed	Normal	Add Rack Protection Status latch and overtemp status latch to rack monitor IOC	Glenn Horton-Smith	10/02/2015 02:27 PM
9066	Feature	Closed	High	Secure Wiener write-access with new community name	Glenn Horton-Smith	10/02/2015 02:37 PM
9022	Feature	Closed	Normal	add Wiener internal temperatures, "behavior" variables to archive	Glenn Horton-Smith	10/02/2015 08:05 PM
8398	Feature	Closed	Normal	Upgrade CSS gui to 3.3.10a (NSLS2 version) for good pv-table save/restore tool	Glenn Horton-Smith	06/01/2015 02:43 AM
8143	Feature	Closed	Normal	Test and document use of EPICS channel save/restore tool	Glenn Horton-Smith	10/02/2015 09:13 AM
8142	Feature	Closed	Normal	Make cryo readonly vars invalid if data is too old	Glenn Horton-Smith	03/23/2015 11:39 AM
8141	Feature	Closed	Normal	Complete slowmoncon expert docs on EPICS and CSS setup	Glenn Horton-Smith	10/02/2015 09:28 AM